

ULTIMATE POWER SOLUTION (FZC) The world's best dealer on Diesel Power Generation, Control Systems & Power Solution

POWERED BY

Perkins

LEROY-SOMER UPS



CERTIFIED BY







600 KVA 3 PHASE 50 HZ

GENERATING SET MODEL (UPS 600P)		
Output Ratings	Prime	Standby
380-415 V, 3 ph, 50 Hz, 1500 rpm	600 KVA 480 KW	660 KVA 528 KW
380-415 V, 3 ph, 60 Hz, 1800 rpm	625 KVA	687 KVA
	500 KW	550 KW

ENGINE / TECHNICAL DATA

Ratings at 0.8 Power Factor

Engine Make	Perkins 2806A-E18TAG1 Electronic		
Engine Model			
Governing Type			
Number of Cylinders	6		
Cylinder Arrangement	Vertical in line		
Bore and Stroke mm	14 <mark>5 x 183</mark>		
Displacement / Cubic Capacity litres	18.1		
Induction System	Turbocharged and air to air charge cooled		
Cycle	4 stroke		
Combustion System	Direct Injection		
Compression Ratio	14:5:1		
Rotation	Anti-clockwise, viewed on flywheel		
Cooling System	Water - cooled		
Frequency and Engine Speed	50Hz & 1500rpm	60Hz & 1800rpm	
Gross Engine Power kW (hp)	584 (783)	628 (842)	
Fuel Consumption @ 50% load L/hr	61	66	
@ 75% load L/hr	90	95	
@ 100% load L/hr	123	127	
Total Lubrication System Capacity litres	62	62	
Total Coolant Capacity litres	61	61	
Exhaust Temperature: °C	555	555	

60 Hz

625 KVA 3 PHASE

ALTERNATOR DATA		
Make	UPS / Leroy Somer	
Model	UPS354E /TAL 047 E	
No. of bearings	1	
Insulation class	Н	
Wires	6/12	
Ingress Protection	IP23	
Excitation System	Shunt	
Winding Pitch	2/3	

Overspeed	2250 mn ⁻¹	
Voltage Regulation (steady)	± 1%	
Short Circuit Capacity	-	

Deep Sea
7000 SERIES


The DSE 7000 Series is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm indications:

- · Generator frequency
- · Underspeed, Overspeed
- · Generator volts (L-L, L-N)
- · Generator current
- · Engine oil pressure
- · Engine coolant temperature
- · Fuel level (Warning or shutdown) Optional
- · Hours run counter
- · Battery volts
- · Fail to start/stop
- Emergency stop
- · Failed to reach loading voltage/frequency
- Charge fail
- · Loss of magnetic pick-up signal Optional
- Low DC voltage
- · CAN diagnostics and CAN fail/error

Image for illustrative purposes only

Tel: +971 6 5570722 Fax: +971 6 5570733





E-mail: info@upsgenerator.com Web.: www.upsgenerator.com

P.O.BOX: 122333 F3-18, Sharjah Airport Free Zone (SAIF ZONE)

STANDARD SPECIFICATIONS

600 KVA 3 PHASE

3 PHASE

50 Hz

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine.

2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filter.
- Two Cartridge type fuel filters.
- Full flow lube oil filter.

All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors)

EXHAUST SYSTEM

Exhaust Gas flow 115 m3/min

6.9 (kPa) Maximum allowable back pressure

5. CIRCUT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

7. ALTERNATOR

7.1 INSULATION SYSTEM

- The insulation system is Class H.
- All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin.
- Heavy coat of antitracking varnish additional protection against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at $\pm 1\%$. Nominal adjustment by means of a trim pot incorporated on the AVR.

8. MOUNTING ARRANGEMENT

8.1 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.2 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.3 SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection

9. FACTORY TEST

- The Generating set is load tested before dispatch
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability

DOCUMENTATION

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDF0530 NEMA MG 1.22 and ISO 8528.


13. WARRANTY


All of the Generating Sets are covered under a warranty policy for a period of 12 months or 1000 working hours. Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries)


In line with continuous product development, we reserve the right to change specifications without notice.

STANDARD GENERATOR DIMENSION AND WEIGHT

Silent Type (with Soundproof Canopy)










Open Type (without Soundproof Canopy)

: +971 6 5570722

: +971 6 5570733







E-mail: info@upsgenerator.com P.O.BOX: 122333 | F3-18, Sharjah Airport Free Zone (SAIF ZONE) Web.: www.upsgenerator.com